CERACASA
CERAMICA

Ceracasa, s.a.
Ctra. Castellón-Teruel, Km.19
12110 ALCORA- Castellón -España
Tel. 964 361 611- Fax 964 360 967
Fax Dpt Export +34 964 362 422
www.ceracasa.com

Alfa De Oro
CEVISAMA 2007

Alcora , October 10, 2018

QUALITY CERTIFICATE

White body wall tiles

Models: DAVOS ARENA BRILLO, DAVOS BLANCO BRILLO, DAVOS PERLA BRILLO.
Reliefs: Plain and Waves
Size: 25 x 73 cm.

CERACASA,S.A. Certifies that the above referenced models are manufactured to meet the Standards UNE-EN 14411, for ceramic tiles dry pressed with water absorption higher than 10% (Group BIII).

After the determination of water absorption test according to UNE-EN ISO 10545-3:1997 (Boil Method) state those results:

AVERAGE WATER ABSORPTION: **14,30%**

As well, according to UNE test control results are:

STAIN RESISTANCE s/ISO 10545-14: **Class 5**
DETERMINATION OF BENDING STRENGTH AND BREAKING LOAD
s/UNE-EN-ISO. 10545-4. Thickness: **9 mm.**
Breaking load, F: **42.35 N.**
Breaking force, S: **1180 N. (Required by S>600 N)**
Bending Strenght, R: **21.37 N/mm2 (Required by R >12N/mm2)**

Complying with all norms corresponding to first quality ceramic tiles dry pressed from previous regulations. These products are in conformity with the provisions of the Annex K to the norms **UNE-EN-14411 : 2013** "Ceramic Tiles, Definitions, Classification, characteristics and marking". **(Group BIII, E>10%)**

Felipe Sierra Grau
CERACASA
Ceracasa, s.a.
Dpto. Quality